HVAC DISTRIBUTING LLC

VERSA PRO
GAS FURNACE 96% AFUE

AVAILABLE IN 60K–120K





VERSA PRO
GAS FURNACE 96% AFUE

- ENERGY EFFICIENT
- 96% AFUE
- SUPERIOR PERFORMANCE
- DURABLE BUILD & FINISH
- INCLUDED LP KIT
- ALL-POSITION
- TWO STAGE
- QUIET OPERATION
- COMPACT DESIGN
- LEAK SENSOR ADAPTABLE

LIFETIME
HEAT EXCHANGER WARRANTY

10 YEAR
PARTS WARRANTY

MRCOOL®
COMFORT MADE SIMPLE

V 10.14.26

HVAC DISTRIBUTING LLC

VERSA PRO GAS FURNACE 96% AFUE SPECIFICATIONS

UPFLOW HORIZONTAL		Unit	MGM96EE060B3NB	MGM96EE080B3NB	MGM96EE080C4NB	MGM96EE100C5NB	MGM96EE120D5NB
PERFORMANCE							
Power Supply		V~Hz, Ph	115~60, 1	115~60, 1	115~60, 1	115~60, 1	115~60, 1
Natural Gas / LP	Input	Btu/h	60,000	80,000	80,000	100,000	120,000
	Output	Btu/h	57,000	76,000	76,000	95,000	115,000
Temp. Rise Range		°F	30-60	35-65	35-65	35-65	40-70
ELECTRICAL							
Min. / Max. Voltage		V	104/127	104/127	104/127	104/127	104/127
Min. Circuit Ampacity		A	8	8	7.8	11.5	10.5
Miax. Overcurrent Protection		A	15	15	15	20	20
DIMENSIONS & WEIGHT							
Cabinet Size (WxDxH)		inch	17.5 x 28.75 x 33.75	17.5 x 28.75 x 33.75	21 x 28.75 x 33.75	21 x 28.75 x 33.75	24.5 x 28.75 x 33.75
Packing Size (WxDxH)		inch	20 x 31.02 x 40.35	20 x 31.02 x 40.35	23.54 x 31.02 x 40.35	23.54 x 31.02 x 40.35	27.05 x 31.02 x 40.35
Net Weight		lbs	135	141	152	162	176
Gross Weight		lbs	147.5	153	165	173	190
FAN MOTOR							
Horsepower		HP	3/4	3/4	3/4	1	1
Max CFM @ 0.5ESP		CFM	1321	1214	1289	1774	1916
Motor Speeds			5 speed	5 speed	5 speed	5 speed	5 speed
CIRCULATOR BLOWER							
Material			Metal	Metal	Metal	Metal	Metal
Size		inch	12.375 x 8	12.375 x 8	12.75 x 11.25	12.75 x 11.25	12.75 x 11.25
Vent Diameter		inch	2“/3”	2“/3”	2“/3”	2“/3”	3”
No. of Burners			3	4	4	5	6
GAS							
Gas Type			NG (LP w/kit)	NG (LP w/kit)	NG (LP w/kit)	NG (LP w/kit)	NG (LP w/kit)
Gas Connection Size		inch	1/2	1/2	1/2	1/2	1/2

FLANGE ADAPTER
MODEL NO.
MCMP1824A-F
MCMP1836B-F
MCMP4860C-F
MCMP4860D-F

AHRI CERTIFIED® www.ahridirectory.org

Data provided by AHRI

c ETL US

Intertek

3124627

All specifications are preliminary and subject to change during mass production.

Equipment sizing and installation must be performed by a licensed HVAC contractor in accordance with ACCA Manual J and applicable local codes.